

SECTION 603

CULVERTS AND STORM DRAINS

Standard Modification

603-1.01 DESCRIPTION. Add the following: This work shall also consist of installing culvert marker posts.

603 2.01 MATERIALS. Add the following: Culvert marker posts shall meet the requirements of subsection 730-2.05, Flexible Delineator Posts. The color shall be blue with no other markings. The 2.5 inch by 6 foot post shall be rectangular in cross section with reinforcing ribs capable of a minimum bending radius of 9 inches.

Add the following:

603 3.06 CULVERT MARKER POSTS. Culvert marker posts shall be installed on the approach side of the storm drain outfalls 30 inches and smaller, field inlets not in paved parking lot, all end sections to cross culverts, or as directed by the Engineer. Forty two inches of post shall remain above the ground after driving.

603 5.01 BASIS OF PAYMENT. Culvert Marker posts, excavation, bedding and backfill are subsidiary.

MSB 020714